


SAW Filters



TMX W235 SAW Bandpass Filter - MEDICAL TELEMETRY
Preliminary Specification (Rev-)



TMX W235

SAW Bandpass Filter - MEDICAL TELEMETRY

Preliminary Specification (Rev-)

<input type="checkbox"/> Technical overview	P01
<input type="checkbox"/> Matching Network Configuration	P01
<input type="checkbox"/> Typical Response (Measurement)	P02
<input type="checkbox"/> Package Drawing	P03



TMX W235

SAW Bandpass Filter - MEDICAL TELEMETRY

Preliminary Specification (Rev-)

May 30th, 2005


Operating temperature range : [0°C; +50°C]

Electrical Parameters		Unit	Minimum	Typical ⁽¹⁾	Maximum
Source Impedance (single ended)	Ω	-	50 ⁽²⁾	-	-
Load Impedance (single ended)	Ω	-	50 ⁽²⁾	-	-
Center Frequency f ₀	MHz	-	611	-	-
- 2 dB Bandwidth	MHz	6	-	-	-
Absolute Attenuation					
0 kHz to 550 MHz	dB	42	48	-	-
550 MHz to 598 MHz	dB	42	46	-	-
598 MHz to 601.5 MHz	dB	45	54	-	-
621 MHz to 900 MHz	dB	45	57	-	-
900 MHz to 1300 MHz	dB	40	48	-	-
1300 MHz to 1800 MHz	dB	30	46	-	-
1800 MHz to 2000 MHz	dB	20	29	-	-
2000 MHz to 3000 MHz	dB	15	20	-	-
Insertion Loss @ f ₀	dB	-	1.9	3.0	-
Amplitude Variation in 608 MHz-614 MHz ⁽³⁾	dB		1.0	1.6	-
Group Delay Variation in 608 MHz-614 MHz	ns		50	100	-
Input / Output VSWR in 608 MHz-614 MHz at 25°C	-	-	1.6:1	2.1 :1	-
Input / Output VSWR in 608 MHz-614 MHz	-	-	1.6:1	2.5 :1	-
Temperature coefficient	ppm/°C	-	-32	-	-
Maximum input power in 608 MHz-614 MHz ⁽⁴⁾	dBm	-	-	30	-
Package type & size					
Length x Width	mm ²	-	5.0 x 5.0	-	-
Height	mm	-	1.6	1.8	-
Pin Out					
Input	2	Output	6		
Case Ground	1,3,4,5,7,8	To Be Grounded	1,3,4,5,7,8		

Notes :

- (1) Typical values are nominal performances at room temperature
- (2) No external matching is required
- (3) The amplitude variation is defined as the maximum level – minimum level over the given bandwidth
- (4) Minimum lifetime @ 50°C, 30dBm CW higher than 50000 hours.

50 Ω / 50 Ω CONFIGURATION



TMX W235





SAW Bandpass Filter - MEDICAL TELEMETRY

Preliminary Specification (Rev-)

May 30th, 2005

TYPICAL S21 RESPONSE

The template indicated is linked to the specification over [0°C; +50°C] temperature range.




TMX W235

SAW Bandpass Filter - MEDICAL TELEMETRY

Preliminary Specification (Rev-)

May 30th, 2005

PACKAGE DRAWING



LAND PATTERN

